

荒川大橋(荒川)

	試験項目		定量 下限値	令和7年								令和8年			年間		
				4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	最高	最低
採水条件	採水日			4月22日													
	採水時刻			9:35													
	天候			快晴													
	気温	℃		19													
	水温	℃		17.3													
一般項目	pH値			7.9													
	導電率	μS/cm	1	200													
	濁度	度	0.1	3.2													
	色度	度	1	9													
	アルカリ度	mg/L	0.2	56.2													
	臭気			藻臭													
	臭気(塩素添加)			-													
	有機物(TOCの量)	mg/L	0.2	1.5													
アンモニア態窒素	mg/L	0.02	0.00														
発色法	シアン	mg/L	0.002	0.000													
	フェノール類	mg/L	0.005	0.000													
	MBAS	mg/L	0.02	0.00													
かび臭	2-メチルイソボルネオール	μg/L	0.002	0.015													
	ジェオスミン	μg/L	0.002	0.000													
VOC等	1,1-ジクロロエチレン	mg/L	0.001	0.000													
	ジクロロメタン	mg/L	0.001	0.000													
	メチルセブチルエーテル	mg/L	0.001	0.000													
	(シス+トランス)-1,2-ジクロロエチレン	mg/L	0.001	0.000													
	クロロホルム	mg/L	0.001	0.000													
	1,1,1-トリクロロエタン	mg/L	0.001	0.000													
	四塩化炭素	mg/L	0.001	0.000													
	1,2-ジクロロエタン	mg/L	0.001	0.000													
	ベンゼン	mg/L	0.001	0.000													
	トリクロロエチレン	mg/L	0.001	0.000													
	ブロモジクロロメタン	mg/L	0.001	0.000													
	1,4-ジオキサン	mg/L	0.01	0.00													
	トルエン	mg/L	0.001	0.000													
	1,3-ジクロロプロペン	mg/L	0.001	0.000													
	1,1,2-トリクロロエタン	mg/L	0.001	0.000													
	テトラクロロエチレン	mg/L	0.001	0.000													
	ジブロモクロロメタン	mg/L	0.001	0.000													
	キシレン	mg/L	0.002	0.000													
	ブロモホルム	mg/L	0.001	0.000													
	総トリハロメタン	mg/L	0.001	0.000													
	ホルムアルデヒド生成能	mg/L	0.005	0.000													
金属類	ホウ素	mg/L	0.02	0.03													
	アルミニウム	mg/L	0.02	0.02													
	クロム	mg/L	0.004	0.000													
	マンガン	mg/L	0.01	0.01													
	ニッケル	mg/L	0.002	0.000													
	銅	mg/L	0.02	0.00													
	亜鉛	mg/L	0.02	0.00													
	モリブデン	mg/L	0.014	0.000													
	カドミウム	mg/L	0.0006	0.0000													
	アンチモン	mg/L	0.0004	0.0000													
	鉛	mg/L	0.002	0.000													
	ウラン	mg/L	0.0004	0.0000													
	鉄	mg/L	0.06	0.00													
	ヒ素	mg/L	0.002	0.000													
	セレン	mg/L	0.002	0.000													
ナトリウム	mg/L	2.5	7.7														
	カルシウム・マグネシウム等(硬度)	mg/L	5	73													
イオン類	硝酸・亜硝酸態窒素	mg/L	0.3	1.4													
	硝酸態窒素	mg/L	0.3	1.4													
	亜硝酸態窒素	mg/L	0.004	0.018													
	フッ素イオン	mg/L	0.05	0.06													
	塩化物イオン	mg/L	3.0	6.4													
	リン酸イオン	mg/L	0.05	0.07													
	臭化物イオン	mg/L	0.05	0.00													
	硫酸イオン	mg/L	3	24													
	塩素酸	mg/L	0.05	0.00													
	亜塩素酸	mg/L	0.05	0.00													
	過塩素酸	mg/L	0.001	0.000													